

Analysis of Reflectors in Concentrated Solar Power Plants

Chandresh Kumar Lodha
M.Tech Scholar

Truba Institute of Engineering & Information
Technology
Bhopal, M.P, India
chandresh232002@gmail.com

Prof. Pankaj Badgaiyan
Assistant Professor

Truba Institute of Engineering & Information
Technology
Bhopal, M.P, India

Abstract: Throughout comparing to limited in time fossil fuels such as coal, petroleum, and natural gas, solar energy is observed to be extremely appealing as a renewable energy source in the twenty-first century due to its unending supply and nonpolluting nature. Concentrating Solar Power is a type of renewable energy that uses the sun's energy to generate electricity and heat. CSP plants can be used for desalination and solar fuel production. Work more productively make up the majority of the applications. Solar Thermal Power Plants (STPPs) are large-scale renewable energy infrastructures that use heat generated by contracted solar beams. The main goal of this paper is to provide a comprehensive literature review on central solar receivers, as well as to investigate terms like solar thermal energy and concentrated solar plants.

Keywords: Solar energy, solar thermal energy, concentrating solar power, Linear Fresnel Reflector and Parabolic Trough.

I. INTRODUCTION

Thermal energy from the sun can be defined as a unilluminated surface soaks up solar energy and warms when exposed to sunlight. A solar thermal collector that operates on this concept does have a surface where sunlight direct falls that transmit some of the energy to a working medium like water or air. Single or dual layers of transparent covers are typically positioned over the absorbing surface and insulation is placed while behind absorber to avoid heat shortfalls to the environment and boost productivity. A flat plate collector is a straightforward solar thermal collector that can raise the temperature of around 100°C.

Concentrating collectors, including a parabolic trough, parabolic dish, or a centralized receiver tower, are being utilized to obtain higher heat waves. Concentrating collectors can attain temperature extremes to 1000°C or even greater. Space heating, air conditioners, high temperature water, process industries heat, drying based process, distillation as well as desalination, and electricity generation are just some of the implementations for solar thermal energy.

Solar thermal energy (STE) is a method of using solar energy to generate heat (heat). Low-, moderate, and elevated-

temperature collectors are the three types of solar thermal collectors. Flat-plate reduced-temperature collectors are commonly employed to heat public pools. Moderate temperature collectors, like flat-plate collectors, are employed to heat water or air for both residential purposes and traditions. High-temperature collectors, which use mirrors to reflect to stay focused sunlight, are commonly used to generate electricity.

II. CONCENTRATING SOLAR POWER

Reflectors are used in Concentrating Solar Power (CSP) techniques to concentrate (focus) the sun's luminous energy and transform it into heat, which is then used to spin a turbine that initiates electricity. CSP technique makes use of concentrated sunlight. CSP Installations initiate electricity by concentrating (focusing) the sun's energy and converting it to elevated-temperature heat utilizing reflectors. The heat is then transferred to a traditional generator. The plants are divided into two sections: one which gathers solar energy and transforms it to warm, and another that transform heat energy into electrical energy.

CSP is a innovation that complements Photovoltaic technique. It adds intense temperature to a traditional power cycle using focusing collectors. Thermal energy storage (TES) technologies that are both effective and inexpensive can be incorporated into CSP systems, permitting electricity to be produced that according requirement profiles. CSP processes can also eliminate the need for "darkness plant capacity" to protect initiation capacity during periods of low sunlight or wind waves, as well as offer grid based services and, if preferred, dark beginning functionality.

As a result, it encourages the use of variable renewable energy sources such as wind and solar power, while avoiding the use of costly electrical energy storage advanced technologies in grid systems. CSP technique was not widely commercialised until 2007, primarily in Spain and the US. Presently, nearly 6 GW of ability is operational, with some other 1.5 GW under

structural applications. Marketplaces in the Mid East and North Africa, as well as South Africa, India, and China, have only awhile back begun to emerge.




Figure 1 (A) Linear Fresnel Reflector and (B) Parabolic Trough

Because light is focused on a sequential recipient in the two categories shown in Figure 1, the above two different types are referred to as line-focus systems, with a highest two dimensional concentration proportion of 210. For isolation, the recipient is usually a steel based tube within an evacuated glass compartment. Although thermal oil as the working fluid, usual initiated temperatures range from 400°C to 600°C, with power conversion efficiency ranging from 8% to 18%.




Figure 2 (C) Central Receiver (D) Parabolic Dish

Figure 2 shows how light is focused to a juncture recipient with a highest three dimensional concentration proportion of 46,000, with traditional receiver temperatures of 800°C (parabolic dish) and 600°C–1200°C (central receiver), and operating medium of molten salts or heat oils. Efficiency improvements vary from 20% to 40%, but higher efficiency comes at the cost of more precise Sun monitoring. CSP is described as power initiated in CSP systems that utilize sunlight concentrators to transmit solar energy into heat, and perhaps a heat engine relying on the Rankine, Brayton, as well as Stirling rotations to transforming the heat into power.




Figure 3 Concept of CSP technologies [J P Bijarniya 2016]

The receiver's highest absorption of incoming radiation is recommended for heating the HTF, which could then boost the temperature of the operating fluid implanted into the turbines, leading to increased productive output. CSP techniques are divided into two groups depending on the concentration geometrical: point focus concentrators and line focus concentrators. The concentration configuration of a Concentration Solar Power system is determined by the geometrical and organizational of the reflectors such as mirrors. Owing to the increase concentration ratio (3000), point focus depending techniques attain greater temperatures (700–1000 °C) at the recipient, so although line focus techniques attain less temperatures (700–1000 °C) due to heat damages in HTF transportation.

The centralized receiver framework, known as a heliostat, at the uppermost layer of a tower is used to concentrate on light from the sun to a recipient in a sun-tracking reflector framework. The recipient is employed to initiate steam in a heat transfer fluid thermal to almost 600 degrees Celsius, and then utilized to initiated electricity in a traditional turbine.




Figure 4 Concentrated Solar Power

III. LITERATURE REVIEW

D. Heringa et al., 2021 [1] In terms of optimizing inherent thermo-mechanical and destroy modelling, the writers believe there is scope for further enhancement over this methodology. Furthermore, a bottom-up approach, while trying to imply more strictly enforced model and handling performance standards, commitments substantially increased commercial feasibility, owing to low safety margins in procedure and condition-based available strategies. Important strategies and presumptions of thermal - mechanical and destroy modelling methods in existing literature are described and evaluated in terms of its potential for the methodology outlined to also be proved at a pilot scale testing site in this article. As a consequence, it is indicated that using elongated analysis tools from the literary works, modelling can be significantly improved. In addition, depending on the model performance and computational budget friendly, a few methodology models may be used instead of more comprehensive thermomechanical modelling for things like actual transceiver geometrical and neighbourhood boundary conditions.

Avila-Marina et al. (2019) [2] This article gives an overview of the main simulation techniques used to assess VA achievement in solar towers. The primary methods and techniques are described and analyzed, including depth information simulated world and the culturally homogenous comparable technique. Alternative model schemes, such as Computational Fluid Dynamics (CFD) and one-dimensional (1D) modeling techniques, are also discussed in detail, as well as the significance of the fluid-porous phase equilibrium position (local thermal equilibrium and non-equilibrium). The main mechanism for calculating radiative heat transfer within the highly permeable step are then characterized.

Pradip Dutta et al. (2017) [3] This report investigates current high-temperature solar receiver innovations used in power dish and new power generation systems. It is also mentioned how much research & design work is needed for increased storage materials and technologies. The super - critical carbon dioxide (s-CO₂) Brayton cycle has recently been suggested as a promising candidate for significantly improved thermal performance at increasing operating temperatures and pressures. It also discusses recent developments and difficulties in the design of renewable transmitter and receiver and heat storage systems for such implementations.

Omar Behar et al. [4], Omar Behar et al., Omar Behar et al., The heliostat field, the solar receiver, and the power conversion system are all major components of central receiver solar thermal power plants, and this paper reviews the most important studies on them. Following a brief overview of Concentrating Solar Power (CSP) technology, the current state and implementations of CRSs are discussed. The next step was to conduct a thorough literature review of existing designs, which included optical, thermal, and thermodynamic analysis, as well as component evaluation techniques. Following that, experimental investigations are conducted to establish design concepts. The final section discusses recent advancements in key components such as heliostats, receivers, and hybrid solar gas turbines, which have boosted many R&D activities involving international collaboration over the last 30 years.

Daishi Takahashi et al. [5] It is crucial to gain engine anti-knock performance in attempt to optimise thermal efficiency. To enhance engine anti-knocking quality, techniques for adjusting engine condensation have been established. Extreme coolant advancement, on the other hand, causes an rise in refrigerating heat loss. As a result, the influence of temperature on whacking and refrigeration heat transfer on every engine block, including the engine head-cylinder, cylinder-liner, and piston, must be clarified. The effects of each part of the engine on engine knocking and cooling heat loss are predicted using computer-aided engineering in this paper. During the intake valve, the quantity of heat received by the mixture of air from of the engine cylinder head, cylinder liner, and piston is calculated. The findings suggest that the cylinder-liner, particularly on the exhaust side, contributes the most thermal energy to the air-fuel mixture. It was discovered that the cylinder liner has the greatest impact on the temperature rise of the air-fuel mixture. Furthermore, throughout the expansion stroke, the amount of heat energy discharged from the combustion gas to the engine cylinder head, cylinder liner, and piston was calculated. The cylinder-liner receives the least amount of heat energy from the combustion gas, as shown by the results.

IV. APPLICATION OF CENTRAL SOLAR RECEIVER

Among the most viable alternatives for replacing fossil fuel - based power plants is to employ a central receiver system (CRS) for electricity generation. Since the eighties, technological improvements on its fundamental sub - systems have exploded. The heliostat field, solar recipient, and power conversion framework are the 3 primary sub-systems of centralized receiver solar thermal power plants that have been evaluated research studies and investigations.

In recent times, CSP technique have indeed been investigated as a potential alternative for the energy generation industry; even so, these systems face additional difficulties in terms of thermal productivity and effectiveness. Photovoltaic system and concentrated solar power (CSP) have been the most advanced techniques in the sector of solar energy initiation; the very first offers decentralized power initiation, while the second offers energy plants with energy storage systems; these are the most appropriate supplies for large-scale energy production.

CSP has the benefit of providing dispatchable renewable electric power with a trying to balance unreliable of renewable energy power, such as wind power and solar photovoltaic supplies, that are variable and necessitate a backup storage framework. Whenever sun hours are accessible, CSP has the alternative of integrating a thermal storage and an energy storage device, that can be utilized after initiation time perhaps at night.

The initial stage of a CSP system consists of converting solar radiation into concentrated radiant energy heat, which is then transmitted to a focal point through rays focused on the framework surface. The second stage connects the central recipient's absorption coefficient from radiant energy to thermal conversion. Eventually, thermal energy is transferred into K.E. (kinetic energy), which is then converted to electricity using a power source.

Systems with centralized recipients

Central receiver systems (also known as solar towers or power towers) are made up of a huge number of two-axis traceability reflectors (heliostats) with a contact area of 20e200 m² apiece, as well as a heat exchanging device (receiver) at the upper edge of a central building. In power stations with a capacity of 10 MWel, the maximum distance between the furthestmost heliostats and the receiver easily exceeds 1 kilometre. To reduce thermal losses, the recipient, which is usually a shell and tube heat exchanging device, can be placed inside a cavity. Air has poor heat transfer properties, making it hard to utilize in tube bundles.



Figure 5 130 MWel Central receiver power plant close to Las Vegas in the US. Brightsource Energy

Since they can obtain greater temperature changes, allowing for more effective steam cycles or eventually greater exergy cycles employing gas turbines at temperature levels above 1000C to even further boost efficiency and throughput, central receiver systems are thought to get a great potential for mid-term reducing costs of electricity especially in comparison to parabolic trough technology. Nevertheless, especially in comparison to parabolic trough innovation, solar tower technology took longer to develop, and by 2018, tower technology accounted for much less than 20% of all commercial CSP plants. Despite this, a wide range of solar tower notions have been evidenced. Except for the heliostat field, the biggest distinction between these notions is the type of heat transfer medium, which dictates the design and choice of all the other elements.

The scientific proof of global warming owing to CO₂ emissions, the threat compared to nuclear energy, as well as the restricted access to resources, all demand that the energy supply be converted into a sustainable energy future. Because solar energy's global radiation possibilities is nearly infinite, it could be one of the most powerful contributors to solving this problem. Only 1% of the Sahara desert could be used for CSP systems, which would be enough to meet today's global energy needs. Because of the low cost electricity and dispatchability of the technology, CSP appears to have a significant impact in Sunbelt countries after 2030.

V. CONCLUSION

Solar energy, in way of comparison to the finite fossil fuels coal, petroleum, and natural gas, is expected to be highly appealing as a renewable energy source in the twenty-first century due to its unending supply and nonpolluting nature. Concentrating Solar Power (CSP) is a type of renewable energy (RE) that generates electricity and heat by harnessing the sun's energy. Desalination and Solar Fuels applications can both benefit from CSP plants. The majority of the applications are large-scale. Solar Thermal Power Plants (STPPs) are large-scale renewable energy infrastructures that use heat generated by contracted solar beams (Concentrated Solar Power, or

CSP). Thus this paper provided comprehensive literature surveys on central solar receiver and also to study about the terms like solar thermal energy and concentrated solar plants.

REFERENCES

- [1] S. P. Digole, M. Karvinkoppa & S. Sanap “Thermal Analysis of Spiral Solar Receiver for Small Central Receiver System: An Experimental and Numerical Investigation” *International Journal of Ambient Energy*, Taylor & Francis & Informa UK Limited, trading as Taylor & Francis Group, 27 Jan 2020, <https://doi.org/10.1080/01430750.2020.1722744>.
- [2] D. Heringa et al. “Monitoring of service life consumption for tubular solar receivers: Review of contemporary thermo mechanical and damage modeling approaches” 15 September 2021.
- [3] V. M. Maytorena et al. “Analysis of the direct steam generation, thermal stresses, and deformations in a tubular receiver of a solar tower” 14 October 2021.
- [4] Zhenghua Rao at el. “Estimating allowable energy flux density for the supercritical carbon dioxide solar receiver: A service life approach” *Applied Thermal Engineering* 182 (2021) 116024. <https://doi.org/10.1016/j.applthermaleng.2020.116024>.
- [5] Meige Zheng at el. “Analysis of tubular receivers for concentrating solar tower systems with a range of working fluids, in exergy optimised flow-path configurations” *Solar Energy* 211 (2020) 999–1016, <https://doi.org/10.1016/j.solener.2020.09.037>.
- [6] M. Laporte-Azcué at el. “Deflection and stresses in solar central receivers” *Solar Energy* 195 (2020) 355–368. <https://doi.org/10.1016/j.solener.2019.11.066>.
- [7] Messaoud Hazmoune at el. “Numerical Analysis of a Solar Tower Receiver Novel Design” *mdpi./journal/Sustainability* 2020, 12, 6957; doi:10.3390/su12176957.
- [8] Ahmed Bilal Awan et al. “Performance enhancement of solar tower power plant: A multi-objective optimization approach” *Energy Conversion and Management*, Volume 225, 1 December 2020, 113378.
- [9] Angélica PALACIOS, Darío AMAYA and Olga RAMOS, “Parabolic Trough Collector with Internal Fractal Fins in Receiver to Increase Thermal Performance in Working Fluid” 29 July 2020
- [10] J. Lilliestam et al., “Policies to keep and expand the option of concentrating solar power for dispatchable renewable electricity,” *Energy Policy*, vol. 116, pp. 193–197, May 2019.
- [11] M.Cagnoli et al. “A CFD-supported dynamic system-level model of a sodium-cooled billboard-type receiver for central tower CSP applications” *Solar Energy*, Volume 177, 1 January 2019, Pages 576-594.
- [12] Alhussein albarbar and Abdullah arar, “Performance Assessment and Improvement of Central Receivers Used for Solar Thermal Plants” 25 June 2019
- [13] A.L.Avila-Marina et al. “Modelling strategies for porous structures as solar receivers in central receiver systems: A review” *Renewable and Sustainable Energy Reviews* Volume 111, September 2019, Pages 15-33.
- [14] G. Picotti, P. Borghesani, G. Manzolini, M. E. Cholette, and R. Wang, “Development and experimental validation of a physical model for the soiling of mirrors for CSP industry applications,” *Sol. Energy*, vol. 173, pp. 1287–1305, Oct. 2018.
- [15] S. Riahi, W. Y. Saman, F. Bruno, M. Belusko, and N. H. S. Tay, “Performance comparison of latent heat storage systems comprising plate fins with different shell and tube configurations,” *Appl. Energy*, vol. 212, pp. 1095–1106, Feb. 2018.